Calvert County Water and Sewerage Division
Cavalier Country Water System
Public Water System Identification Number (PWSID): 0040002
2008 Annual Drinking Water Quality Report

Dear Customer:

We are pleased to present a summary of the quality of the water provided to you during the past year. The Safe Drinking Water Act (SDWA) requires that utilities issue an annual "Consumer Confidence" Report (CCR) to customers in addition to other notices that may be required by law. This report details where our water comes from, what it contains, and the risks our water testing and treatment are designed to prevent. The Calvert County Water and Sewerage Division is committed to providing you with the safest and most reliable water supply. Informed consumers are our best allies in maintaining safe drinking water.

Overview

In 2008 the Cavalier Country water system enjoyed another year of perfect compliance with all applicable drinking water standards. We continued our relationship with the American Water Works Association to ensure continued excellence.

Water Source

The Cavalier Country water system is supplied by two wells in the Magothy Aquifer. The water is chlorinated to ensure bacteriological purity. Other than chlorination, we do not treat the water, as it meets drinking water standards naturally.

An Explanation of the Water Quality Data Table

The table shows the results of our water quality analysis. Every regulated contaminant that we detected in the water, even in the most minute traces, is listed here. The table contains the name of each substance, the highest level allowed by regulation (Maximum Contaminant Level, or MCL), the ideal goals for public health, the amount detected, the usual sources of such contamination, footnotes explaining our findings, and a key to units of measurement. Definitions of MCL and Maximum Contaminant Level Goal (MCLG) are important.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Key to Table

AL = Action Level
MCL = Maximum Contaminant Level
MCLG = Maximum Contaminant Level Goal

pCi/L = picocuries per liter (a measure of radioactivity)
ppm = parts per million, or milligrams per liter (mg/L)
ppb = parts per billion, or micrograms per liter (ug/L)

Substance	Date Tested	Unit	MCL	MCLG	Level Detected	Possible Sources	Violation
Fluoride	12/10/08 06/17/08	ppm	*SMCL 2.0	-	0.2 0.2	Erosion of natural deposits	NO
Copper	12/31/08	ppm	AL = 1.3	1.3	0.15	Corrosion of household plumbing systems	NO
Iron	12/11/08	ppm	*SMCL 0.3	0.3	1.5	N/A	NO
Total Trihalomethanes	09/27/07	ppb	80	***	1.6	By product of drinking water disinfection	NO
Lead	12/31/08	ppm	AL = .015	0	.002	Corrosion of household plumbing systems	NO
Radium-226	12/10/08	pCi/L	5.0	0	1.0	Erosion of natural deposits	NO
Radium-228	12/10/08	pCi/L	5.0	0	1.1	Erosion of natural products	NO

Well (Continued)

Substance	Date Tested	Unit	MCL	MCLG	Level Detected	Possible Sources	Violation
Gross Alpha	12/10/08	pCi/L	15	0	4.0	Erosion of natural deposits	NO
Gross Beta	12/10/08	pCi/L	13	0	6.0	Decay of natural and man-made products	NO
Sodium	12/11/08 06/17/08	ppm	**DWEL 20	-	6.3 6.3	N/A	NO
Di(2-ethylhexyl) phthalate	06/28/05	ppb	6.0	0	0.8	Discharge from rubber and chemical factories	NO
Barium	06/17/08	ppm	2	2	0.07	Discharge from drilling waste	NO
Chloroform	06/28/05	ppb	80	-	0.8	By product of drinking water disinfection	NO
Haloacetic acids	09/27/07	ppb	60	***	3.3	By product of drinking water disinfection	NO

****SMCL (Secondary Maximum Contaminant Level)**: Secondary standards are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects, such as taste, odor or color.

*****DWEL (Drinking Water Equivalent Level)**: A lifetime exposure concentration protective of adverse, non-cancer*ous* health effects, which assumes all the exposure to a contaminant is from a drinking water source.

***Although there is no collective MCLG for this contaminant group, there are individual MCLGs for some of the individual contaminants:

Haloacetic acids: dichloroacetic acid (zero); trichloroacetic acid (0.3mg/L)

Trihalomethanes: bromodichloromethane (zero); bromoform (zero); dibromochloromethane (0.06mg/L)

Water Quality Table Footnotes

The lead and copper results are reported from tests taken within customers' dwellings. There is no lead and copper in the raw water. Although we ran tests for many constituents, only the listed substances were found. They are all below the MCL required.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Calvert County Water and Sewerage is responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using the water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the U.S. Environmental Protection Agency (EPA) Safe Drinking Water Hotline at (800) 426-4791 or at http://www.epa.gov/safewater/lead.

Required Additional Health Information

To ensure that tap water is safe to drink, EPA prescribes limits on the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

(A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

(B) Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

(C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, stormwater runoff, and residential uses.

(D) Organic chemical contaminants, including synthetic and volatile organics, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.

(E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than is the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly persons, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline by calling (800) 426-4791.

Source Water Assessment

The Maryland Department of the Environment's Water Supply Program (WSP) has conducted Source Water Assessments for 36 community water systems in Calvert County, including the Cavalier Country water system. The required components of this report as described in Maryland's Source Water Assessment Program (SWAP) are 1) delineation of an area that contributes water to the source, 2) identification of potential sources of contamination, and 3) determination of the susceptibility of the water supply to contamination. Recommendations for protecting the drinking water supply conclude this report.

The susceptibility analysis is based on a review of the existing water quality data for each water system, the presence of potential sources of contamination in the individual assessment areas, well integrity, and aquifer characteristics. It was determined that the Cavalier Country water supply is not susceptible to contaminants originating at the land surface due to the protected nature of confined aquifers.

National Primary Drinking Water Regulation Compliance

This report was prepared using CCR Builder and technical assistance provided by the American Water Works Association. We'll be happy to answer any questions about Calvert County Water and Sewerage Division and the water quality in the Cavalier Country water system. Call Barry King, (410) 535-1600, ext. 2329, Monday through Friday, 8 a.m. – 4 p.m.