

Vicki Crosby

Technical Services Manager DeNeef Products

December 3, 2013

Adam M. Dyer, PE
Geotechnical Engineer
Mueser Rutledge Consulting Engineers

Re: SWELLSEAL[®] WA performance

Dear Mr. Dyer:

The performance of Swellseal WA will not be affected by the presence of hexavalent chromium in the soil/ground water at the jobsite.

Please contact me if you need additional information.

Best regards,

Vicki C. Crosby

Vicki C. Crosby
Technical Services Manager
DeNeef Construction Chemicals

cc: Scott Anderson, Roger Burris- Grace Construction Products

GRACE