

Department of the Environment


Tracking "Performance Credit" for Point Source

October 5, 2016

Maryland Water Quality Trading Committee Meeting



Waste Load Allocation



Annual Maximum Nutrient Loads Assigned from TMDL to a WWTP



Permit Requirement – WLA

Permit No. 14-DP-0106 (NPDES MD0020958)

Page No. 6 of 35

II. SPECIAL CONDITIONS

A. Effluent Limitations, Outfall 001A (1) (2) (3) (4)


The quality of the effluent discharged by the facility at a discharge point location-001A shall be limited at all times as shown below:

	Maximum Effluent Limits							
	Monthly Average Loading Rate,	Weekly Average Loading Rate,	Daily Average Loading Rate,	Monthly Average Concentration,	Weekly Average Concentration,	Daily Average Concentration,		
Effluent Characteristics	Pounds/day	Pounds/day	Pounds/day	mg/l	mg/l	mg/l		
BOD ₅	350	530	N/A	30	45	N/A		
TSS	350	530	N/A	30	45	N/A		
				n Effluent Limits				
	Total Monthly			Annual Maximum		Monthly Average		
Effluent Characteristics	Loading Rate, Pounds/Month			Loading Rate, Pounds/Year		Concentration, mg/l		
TSS	REPORT REPORT			127,914				
Total Phosphorus-P (5)(6) (7)				1,279	REPORT			
Total Nitrogen-N (2)(0) (7)	RI	EPORT		17,055	REPORT			
	Effluent Limits							
Effluent Characteristics	Maximum			Minimum				
E. Coli	126 MPN/ 100 ml monthly geometric mean value			N/A				
Total Residual Chlorine (8)	Nondeted	table level (See	footnote- 8)	N/A				
pH	8.5			6.5				
Dissolved Oxygen	N/A			5.0 mg/l at anytime				

An annual average flow of <u>1.4</u> million gallons per day (mgd) was used in waste allocation calculations (expressed as waste loading rate limit), and this unit shall be used when reporting on the Discharge Monitoring Report (DMR), (EPA Form 3320-1, Rev. 01/06). Notification is to be provided to the Department at least 180 days before the annual average flow is expected to exceed this flow level. If a permit modification is required, the Department will initiate the public participation NPDES process.



Floating Cap



(Annual Total Flow) × (ENR Performance Criteria*)

A discharge requirement to ensure the facility is continuous operating at ENR level

* <u>4 mg/L</u> for Total Nitrogen & <u>0.3 mg/L</u> for Total Phosphorus



Permit Requirement – Floating Cap

Permit No. 14-DP-0106 (NPDES MD0020958)

Page No. 7 of 35

II. SPECIAL CONDITIONS

A. Effluent Limitations, Outfall 001A, Continued:

Footnotes for effluent limitations:

- (1) When this permit is renewed, the new limitations may not be equal to the above limitations.
- (2) There shall be no discharge of floating solids or visible foam other than trace amounts.
- (3) The permit may also be reopened in accordance with the requirements of MDE's Watershed Permitting Plan under which all discharge permits in a watershed are issued the same year.
- The Potomac River Frederick County is on the 303(d) list as the impaired waters for mercury and PCBs in fish tissue. There are no approved TMDLs to address these impairments. This permit is in conformance with the "Chesapeake Bay TMDL for Nitrogen, Phosphorus and Sediment" established on December 29, 2010.
 - When TMDLs for other remaining parameters are completed, limits may be imposed, after the public participation process, to incorporate any TMDL requirements.
- (5) The permittee shall operate the ENR facility in a manner that optimizes the nutrient removal capability of the facility as stipulated in the Grant Agreement for ENR upgrade.
 - The first exceedance of the permit limit shall be counted and reported as daily exceedances beginning from the first exceedance, determined to the nearest day, through December 31. In addition, after any such exceedance, the permittee shall demonstrate to the Department's satisfaction that the facility is optimizing its nutrient removal capability, and neither the arrival of the next calendar year nor the issuance of a permit renewal during a period of noncompliance shall obviate continuance of any noncompliance status related to treatment optimization requirements.
- At the end of each calendar year, the permittee shall comply with the concentration-based limitations for the Annual Maximum Loading Rate defined below or the Tributary Strategy-based loading rate limitation listed in above in the effluent limitations table, whichever is lower?
 - (a) TN Limitation (lbs/year): 4.0 mg/l x annual total flow (calendar year based in million gallons per year) x 8.34. To the extent that the permittee alleges that temperature levels of 12 degrees C or lower have diminished the treatment system's capability of complying with this concentration-based loading rate limitation for Total Nitrogen, the permittee shall provide notification beginning with the calendar year report under the "Upset" provision in Section III. B. 6 of this permit. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.
 - (b) TP Limitation (lbs/year): 0.30 mg/l x annual total flow (calendar year based in million gallons per year) x 8.34.


The details and results of all required annual calculations shall be submitted to the Department with the Discharge Monitoring Report for December. See Special Condition II. J for further details.


The concentration-based loading requirements may be revised if the limits or schedule are determined to be impracticable based on actual performance and the Department re-opens the permit as a major modification (which requires public participation) to impose (an) alternate effluent limitation(s) or revised schedule.

- The permittee may request that the permit be reopened and modified to include nutrient trading consistent with the most current "Maryland Policy for Nutrient Cap Management and Trading in Maryland's Chesapeake Bay Watershed" in effect at that time.
- (8) Total residual chlorine limitation of the nondetectable level shall be applicable, when chlorine or any chlorine-containing compound is used in any treatment process(es), including but not limited to disinfection, that could become a potential constituent of the effluent discharged from the Brunswick WWTP. The wastewater shall be dechlorinated to reduce effluent total residual chlorine concentration to the nondetectable level (See definition LIM).

Annual Cumulative Loads (ACL)

Cumulative Monthly Loads Reported by the Facility Over Calendar Year







Permit Requirement – Nutrient Monitoring

Permit No. 14-DP-0106 (NPDES MD0020958)

Page No. 8 of 35

II. SPECIAL CONDITIONS

B(1). Minimum Monitoring Requirements:

The effluent characteristics listed below in Table B(1) shall be monitored at the sampling point (Definition I.R). If the sampling point is other than the outfall 001A, the permittee shall ensure that the effluent samples are representative of the effluent quality being discharged at the outfall 001A.

Effluent Characteristics	Monitoring Period	Measurement Frequency	Sample Type		
BOD ₅ (9)(18)	All Year	Two per week	24-hour composite		
Total Suspended Solids (9)(18)	All Year	Two per week	24-hour composite		
Total Ammonia Nitrogen as N (9)(10)(11)(18)	All Year	Two per week	24-hour composite		
Total Phosphorus as P (9)(11)(12)(18)	All Year	Two per week	24-hour composite		
Total Nitrogen as N (9)(11)(12)(18)	All Year	Two per week	Calculated		
(Nitrite + Nitrate) as N (9)(10)(11)(18)	All Year	Two per week	24-hour composite		
Organic Nitrogen as N (9)(10)(11)(18)	All Year	Two per week	24-hour composite		
Orthophosphate as P (9)(10)(18)	All Year	Two per week	24-hour composite		
E. Coli (9)(18)	All Year	One per week	Grab		
Total Residual Chlorine (9)(13)(14)	All Year	Two per day	Grab		
Dissolved Oxygen (9)(14)	All Year	Two per day	Grab		
pH (9)(14)	All Year	Two per day	Grab		
Flow (9)(15)(16)	All Year	Continuous	Recorded (16)		
Total Monthly Flow (9)(17)	All Year	Monthly	Calculated (17)		



Permit Requirement – Reporting Annual Total Load & Annual Total Flow

Permit No. 14-DP-0106 (NPDES MD0020958)

Page No. 19 of 35

II. SPECIAL CONDITIONS

H. Protection of Water Quality

It is a violation of this permit to discharge any substance not otherwise listed under the permit's "Effluent Limitations and Monitoring Requirements" special conditions at a level which would cause or contribute to any exceedance of the numerical water quality standards in COMAR 26.08.02.03 unless the level and the substance were disclosed in writing in the permit application prior to the issuance of the permit. If a discharge regulated by this permit causes or contributes to an exceedance of the water quality standards in COMAR 26.08.02.03, including but not limited to the general water quality standards, or if the discharge includes a pollutant that was not disclosed or addressed in the public record for the permit determination, the Department is authorized to modify, suspend or revoke this permit or take enforcement action to address unlawful discharges of pollutants.

Reapplication for a Permit

No later than 12 months before the expiration date of this permit, unless permission for a later date has been granted by the Department, the permittee shall submit a new application for a permit or notify the Department of the intent to cease discharging by the expiration date. In the event that a timely and complete reapplication has been submitted and the Department is unable, through no fault of the permittee, to issue a new permit before the expiration date of this permit, the terms and conditions of this permit continue and remain fully effective and enforceable. The renewal application is required by that date in accordance with the requirements of MDE's Watershed Permitting Plan under which all discharge permits in a watershed should be issued in the same year.

J. Reporting Nutrient Total Annual Loads to Comply with Concentration-based Annual Loading Rate Limits

The Permittee shall report the concentration-based (also known as Floating Cap) annual loading requirements for TN and TP on the December DMR designated "001-Z". The Department will generate the pre-printed DMR forms that will include a separate DMR form for the month of December with this designation. For each calendar year, the permittee shall calculate the annual concentration-based loads for TN and TP as per the footnote-6 of the Special Condition II.A, and report these loadings along with the total annual cumulative flow on the December month DMR forms in accordance with the General Condition III.A.2.a of this discharge permit. If the Brunswick WWTP discharges effluent at more than a single outfall, the total annual loads for TN, TP and total annual discharge flow shall be reported as a sum of the individual results from each outfall.



MDE Worksheet*: Annual Load, Annual Flow & Floating Cap Calculation

Calculation Form for TN, TP and TSS Annual Loads

Facility Name: Brunswick Wastewater Treatment Plant			State Permit Number: 14-DP-0106				NPDES Number: MD0020958				
EAR Rep	orting:	2015									
			To	Total Nitrogen (TN) as N		Total Phosphorus (TP) as P			Total Suspended Solids (TSS)		
	Months	Total Monthly Effluent Flow Million Gallons (MG)	Monthly TN Average Concentration	Monthly TN Loading Rate (1) (Pounds/month)	Year-to-date Cumulative TN Loading ⁽²⁾ YTD (Pounds)	Monthly TP Average Concentration (mg/L)	Monthly TP Loading Rate (1) (Pounds/month)	Year-to-date Cumulative TP Loading ⁽²⁾ YTD (Pounds)	Monthly TSS Average Concentration (mg/L)	Monthly TSS Loading Rate (1) (Pounds/month)	Year-to-date Cumulative TSS Loading ⁽²⁾ YTD (Pounds)
	January	18.387	2.3	314	314	0.23	31	31	0.2	27	27
	February	11.628	2.13	207	521	0.10	10	41	6.6	640	667
1	March	21.488	2.1	376	897	0.20	36	77	0.7	125	793
i	April	14.126	1.98	231	1128	0.30	35	112	0.2	24	816
[May	13.804	2	232	1360	0.31	36	148	0.2	23	840
[June	18.139	2.3	348	1708	0.40	61	208	0.3	45	885
[July	18.711	2.88	306	2014	0.20	23	231	0.2	23	908
	August	12.362	2.02	208	2222	0.20	21	252	0.4	41	949
	September	11.837	2.21	214	2437	0.20	19	271	0.2	19	968
	October	18.006	2.99	399	2836	0.10	13	285	0.2	27	995
	November	13.694	2.64	288	3124	0.10	11	296	0.4	45	1040
	December	18.8	2.24	351	3475	0.10	15	311	0.4	63	1103
:ffluent Tota MG/Year) ⁽³⁾	al Annual Flow	181.748									
Annual average TN, TP and TSS concentrations, (mg/L) = Total Annual Load / (Total Annual Flow x 8.34)		2.3	<meets flo<="" td="" tn=""><td>ating Cap Limit</td><td colspan="2">Limit 0.2 <meets cap="" floating="" limit<="" td="" tp=""><td>0.7</td><td></td><td></td></meets></td></meets>	ating Cap Limit	Limit 0.2 <meets cap="" floating="" limit<="" td="" tp=""><td>0.7</td><td></td><td></td></meets>		0.7				
									1		
WASTE LOADING		POLLUTANT									
		TN			TP		TSS				
Pollutant's Total Annual Load in Effluent discharged		3475			311			1103			
from Facility (Pounds) (4)		0.110						1.00			
Maximum Allowable Annual Loading Rate (Pounds/Year) (5)		6063			455			127914			
TMDL/Tributary Strategy Based Annual Maximum		GOAL = LIMIT =		GOAL = LIMIT =		LIMIT =					
Waste Load Allocation (Pounds/Year)		17055		1279		127914					
Concentration-Based Annual Maximum C _N (m		C _N (mg/L) =			Co (mg/L) =	$C_P (mg/L) = L_P (Pounds/Year)^{(6)} =$		TSS (mg/L) = Load Limit (Pounds/Year		ounds/Year\:	
oading Rate Limit (Pounds/Year) 4.0			163	0.30 455			N/A N/A				
	•	s/Month) = Total Mont					4.	,,,	NA	N	in.
		(Pounds) = Sum of To									
		ım of total monthly flo									
	•	= Year-to-date cumu									
_		ading rate is equal to				Concentration-b	ased annual ma	ximum loading r	ate limits.		
			and the same								
		Maximum Load Limit: Effluent Flow x 8.34 (Where C _N is Trib	utary Strategy b	ased TN concent	ration of 4.0 mg/l	or as specified in	n the permit. If n	ot applicable, set	Cn = 0.0 & Ln = 1	N/A)

Page 1 of 2



^{*} Available to permittee upon permit issuance

Example – Reporting Annual Total Cumulative Flow



CITY OF BRUNSWICK

1 W. Potomac Street · Brunswick, Maryland 21716 · (301) 834-7500

March 17, 2016

Nitrogen and Phosphorus Limitations for 2015

The total cumulative flow for the year 2015 at the City Of Brunswick WWTP (07-DP-0106 NPDES MD0020958): 181.784 mg. Based upon this flow, our limits for 2015 are:

Total Nitrogen Limitations (lbs/yr)
Total Phosphorus Limitation (lbs/yr)

4.0 x 181.784 x 8.34 = <u>6064lbs.</u> 0.3 x 181.784 x 8.34 = <u>455 lbs.</u>

Total Annual Cumulative T. Nitrogen Load Total Annual Cumulative T. Phos. Load

3474 *lbs.* 314 *lbs.*


This a revised flow and loading report from what was sent 1/15/2016.

City of Brunswick MD WWTP 1 West Potomac Street Brunswick, MD 21716

Patrick Hoffmaster, Superintendent




Excess WLA -Available for non-MS4 Trade






Performance Credit –MS4 Trade Only







Tracking Tool (1) Enforcement Compliance History Online (ECHO)





Tracking Tool (2) Integrated Compliance Information System (ICIS)







Questions





Yen-Der Cheng, Chief

Municipal Surface Discharge Permits Division Wastewater Permits Program

Email: Yen-Der.Cheng@maryland.gov

Voice: 410-537-3363

Fax: 410-537-3163

