

Villas at Cattail Creek

2010 Drinking Water

Quality Report

PWSID: 013 0005



Important Information About Your Drinking Water

We're pleased to present to you the Annual Water Quality Report for 2010. This report is designed to inform you about the water quality and services we deliver to you every day. Maryland Environmental Service (MES), an Agency of the State of Maryland, operates the water treatment facility and prepared this report on behalf of Villas at Cattail Creek.

Our goal is to provide you with a safe and dependable supply of drinking water. We encourage you to take the time to read this report and learn more about the quality of your drinking water. Last year more than 800 tests for over 120 different compounds were conducted on the water in Villas at Cattail Creek. MES is dedicated to consistently providing drinking water that meets or exceeds State and Federal regulations. We're happy to report that your drinking water meets all State and Federal requirements.

If you have any questions about this report or have questions concerning your water utility, please contact Jay Janney at 410-729-8350, e-mail jjann@menv.com.

For More Information:

For the opportunity to ask more questions or participate in decisions that may affect your drinking water quality, please contact Liz Hagerty the resident manager with Villas at Cattail Creek at 301-468-8919.

The Villas at Cattail Creek water works consists of two wells in the Sykesville formation. After the water is pumped out of the wells disinfectant is added to protect against microbial contaminants. The Maryland Department of the Environment has performed an assessment of the source water. A copy of the results is available. Call Maryland Environmental Service at 410-729-8350

Inside This Issue:

Definitions	2
Special Points of Interest	2
Radon	2
Water Quality Report	3
Sources of Drinking Water	4
Alpha Emitters	4
Lead Prevention	4

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the **Safe Drinking Water Hotline (1-800-426-4791)**.

Villas at Cattail Creek Treated Water Quality Report 2010

Definitions:

- ◆ **Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- ◆ **Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ◆ **Action Level** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow
- ◆ **Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water
- ◆ **Turbidity** - Relates to a condition where suspended particles are present in the water. Turbidity measurements are a way to describe the level of "cloudiness" of the water.
- ◆ **pCi/l** - Picocuries per liter. A measure of radiation.
- ◆ **ppb** - parts per billion or micrograms per liter
- ◆ **ppm** - parts per million or milligrams per liter



Special points of interest:

The water at Villas at Cattail Creek is tested for over 120 different compounds.

The Villas at Cattail Creek Drinking Water met all of the State and Federal requirements

Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some compounds. The presence of these compounds does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **Environmental Protection Agency's (EPA's) Safe Drinking Water Act Hotline (1-800-426-4791)**

RADON:

We constantly monitor the water supply for various constituents. We have detected radon in the water supply on a sample collected November 7, 2007. At this time, there is no Federal Regulation for radon levels in drinking water. Compared to radon entering the home through soil, radon entering the home through tap water will in most cases be a small source of radon in indoor air. Exposure to air transmitted radon over a long period of time may cause adverse health effects. The radon result of the November 2007 sample was 918 pCi/l (pCi/l = picocuries per liter, a measure of radioactivity). For additional information call the EPA radon hotline at 1-800-SOS-RADON.

Villas at Cattail Creek Treated Water Quality Report 2010

Contaminant	Highest Level Allowed (EPA's MCL)	Highest Level Detected	Ideal Goal (EPA's MCLG)
Regulated at the Treatment Plant - Southwest of Glenwood - Plant I.D. 01			
Well #1 & 2:			
Gross Beta - (2008 Testing)	50 pCi/l*	3 pCi/l**	0.0 pCi/l
Typical Source of Contamination: Erosion of natural deposits			
*EPA considers 50 pCi/L to be the level of concern for beta particles			
** Because the beta particle results were below 50 pCi/l, no testing for individual beta particle constituents was required			
Gross Alpha (2008 Testing)	15 pCi/l	1 pCi/l	15 pCi/l
Please see page 4 of CCR for more details on Gross Alpha Emitters			
Combine Radium (226 & 228) (2006 Testing)	5 pCi/l	0.2 pCi/l	0 pCi/l
Typical sources of contaminant: Erosion of natural deposits			
Nitrate (range 3.64 ppm - 4.6 ppm)	10 ppm	4.02 ppm*	10 ppm
Typical Source of Contamination: Runoff from fertilizer use; erosion			*average
Barium	2000 ppb	8 ppb	2000 ppb
Typical Source of Contamination: Erosion of natural deposits			
Di (2-Ethylhexyl) phthalate (2005 Testing)	6 ppb	0.6 ppb	0 ppb
Typical Source of Contamination: PVC plastics			
Regulated at the Distribution System			
Total Trihalomethanes (TTHMs)	80 ppb	5.78 ppb	n/a
(Ranges from 0.54 ppb - 5.78 ppb) (2008 Testing)			
Typical Source of Contamination: By-product of drinking water disinfection			
Regulated at the Consumer's Tap			
Copper	1300 ppb (action level)	4 ppb	1300 ppb
Typical Source of Contaminant: corrosion of household plumbing fixtures and systems			90th percentile

The table above lists all the drinking water contaminants that were detected during the 2010 calendar year.

The presence of these compounds in the water does not necessarily indicate that the water poses a health risk.

Unless otherwise noted, the data presented in the table is from testing done January 1 – December 31, 2010.

The State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain compounds in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.



Lead Prevention

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Villas at Cattail Creek is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Important information Regarding Gross Alpha Emitters:

Alpha emitters are naturally occurring radiations in soil, air and water. These emitters generally occur when certain elements decay or break down in the environment. The emitters enter drinking water through various methods including the erosion of natural deposits. There are no immediate health risks from consuming water that contains gross alpha, however some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer. Currently, the highest level of gross alpha detected is 1 pCi/L which is below the 15 pCi/L MCL..

If you have any questions about this report or your drinking water, please call Jay Janney at 410-729-8350 or email your request to jjann@menv.com.

