

*Annual Drinking Water Quality Report 2015*

**TOWN OF PITTSVILLE**

**JUNE 2016**

**PWSID #022-0009**

We are very pleased to provide you with this year's Annual Quality Water Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is two wells approximately 115 feet deep in Manokin aquifer located at the Water Treatment Facility on Gumboro Road.

We are pleased to report that our drinking water is safe and meets federal and state requirements.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If you have any questions about this report or concerning your water utility, please contact one of our Water Plant Operators, 410-835-2386. We want our valued customers informed about their water utility. If you want to learn more, please contact our Town office, 410-835-8872 and leave a message for our administrative officer. You may attend any of our regularly scheduled Town Commissioner meetings. They are each third Monday, 7:30 p.m. at the Town Office Building, 7505 Gumboro Road.

The Town of Pittsville Water Treatment Facility routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2015. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*-Non-Detects (ND)* - laboratory analysis indicates that the constituent is not present.

*-Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.



-Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

-Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

-Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

-Maximum Contaminant Level - (mandatory language) The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

-Maximum Contaminant Level Goal - (mandatory language) The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety

### TEST RESULTS

Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>						
Copper	N	0.19 ppm	.19	AL= 1.3		Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	N	0 ppb	0	AL=15		Corrosion of household plumbing systems, erosion of natural deposits
<b>Violated Contaminants</b>						
TTHM (Total trihalomethanes)	N	14/14	ppb	0	80	By-product of drinking water chlorination.
HAA5 (Haloacetic Acids)	N	18/18	ppb	0	60	By-product of drinking water chlorination.

### Unregulated Contaminants

Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Sodium	N	11 ppm	N/A	N/A		Erosion of natural deposits
Chromium	N	7.7 ppb	100	N/A		Erosion of natural deposits
Chloroform	N	4.6 ppb	N/A	N/A		By-product of drinking water
Bromodichloromethane	N	1.4 ppb	N/A	N/A		By-product of drinking water
Chloromethane	N	2.4 ppm	N/A	N/A		Unknown

As you can see by the table, our system had no violations. We are proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected. The EPA has determined that your water IS SAFE at these levels.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk.



If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Pittsville is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

In our continuing efforts to maintain a safe and dependable water supply it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements.

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for understanding.

Please call our office if you have questions.

We at the Town of Pittsville Water Treatment Facility work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

