



Hart Heritage

2017 Annual Drinking Water Quality Report

MD0120021

Is my water safe?

Hart Heritage is pleased to provide this annual water quality report for calendar year 2016. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our system is currently in violation of the Lead and Copper Rule (LCR); we were cited for failing to provide lead results to the consumer in a timely manner. We are actively working to return to compliance status.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from and what are the potential sources of contamination?

Your drinking water is supplied by one well located in the Metagravwacke Wissahickon Formation. The susceptibility analysis for Hart Heritage's water supply is based on a review of the water quality data, potential sources of contamination, aquifer characteristics, and well integrity. For more information on the source of your water, the significant potential sources of contamination, and susceptibility analysis, contact the Maryland Source Water Assessment Program at the Maryland Department of the Environment at (410) 537-3714 or visit on the web at: www.mde.maryland.gov

Why may there be contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

1. Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
 2. Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
 3. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
 4. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
 5. Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.
- In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Important Drinking Water Definitions:

MCLG: Maximum Contaminant Level Goal. The level of a contaminant in drinking water below which there is no known or expected risks for safety. MCLG allows for margin of safety.

MCL: Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: Action Level. The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Units of Measurement & Conversions:

NA: Not applicable

ppm: parts per million, or milligrams per liter (mg/L)

pCi/L: picocuries per liter (a measure of radioactivity)

ppb: parts per billion, or micrograms per liter (µg/L)

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected in your water. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, may be up to five years old.

Contaminant	Date Sampled	MCLG	Action Level (AL)	90 th Percentile	# sites over AL	Units	Violation	Typical Source
Copper		1.3	1.3	0.3	0	ppm		Erosion of natural deposits; leaching from wood preservatives; corrosion of household plumbing systems

Contaminant (units)	Collection Date	MCLG	MCL	Highest Level Detected	Range		Violation	Typical Source
					Low	High		
Inorganic Contaminants:								
Nitrate as Nitrogen (ppm)		10	10	3	3.1	3.1	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Violation Type	Violation Begin	Violation End	Violation Explanation
Lead Consumer Notice (LCR)	01/01/2014		We failed to provide the results of lead tap water monitoring to the consumers at the location water was tested. These were supposed to be provided no later than 30 days after learning the results

Lead

If present, elevated levels of lead can cause serious health problems, especially in pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hart Heritage is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Nitrate

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

Copper

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Hart Heritage

For additional information or questions contact:

Kenneth Joe Skidmore

(410) 836-1295

Prepared by: Water Testing Labs of Maryland, Inc.

For more information on contaminants in drinking water and its effects go to www.wtlmd.com