

# Cheltenham Youth Facility

## 2022 Drinking Water

### Quality Report

PWSID: 016-0003



## Important Information About Your Drinking Water

We're pleased to present to you the Annual Water Quality Report for 2022. This report is designed to inform you about the water quality and services we deliver to you every day. Maryland Environmental Service (MES), an Agency of the State of Maryland, operates the water treatment facility and prepared this report on behalf of Cheltenham Youth Facility.

The Environmental Protection Agency (EPA) regulates Public Water Systems and the contaminants found in water through the implementation of the Safe Drinking Water Act (SDWA). The SDWA sets regulations and guidelines for how public water systems operate and identifies several hundred drinking water contaminants, establishes monitoring frequencies and limitations. The Maryland Department of the Environment (MDE) is responsible for the enforcement of the SDWA and routinely complete Sanitary Surveys as part of their ongoing inspection and monitoring program. MES provides safe dependable operations of the water system and is dedicated to consistently providing high quality drinking water that meets or exceeds the SDWA standards.

If you have any questions about this report or have questions concerning your water utility, please contact **Jay Janney** at **410-729-8350**, e-mail [jjanney@menv.com](mailto:jjanney@menv.com).

### For More Information:

For the opportunity to ask more questions or participate in decisions that may affect your drinking water quality, please contact **Mr. Ron Smallwood** the **Chief of Maintenance for the Cheltenham Youth Facility** at **301-653-6743**.

**T**he water for Cheltenham Youth Facility water works consists of three drilled wells in the Magothy aquifer, a treatment facility, a 250,000 gallon elevated water storage tank and a distribution network. The treatment facility consist of a chemical feed facility designed to disinfect the water. The Maryland Department of the Environment has performed an assessment of the source water. A copy of the results is available. Call **Maryland Environmental Service** at **410-729-8350**.

### Inside This Issue:

Definitions	2
Lead Prevention	2
Water Quality Report	3
Sources of Drinking Water	4
Gross Alpha	4
Polyfluoroalkyl Substances	5

**S**ome people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the **Safe Drinking Water Hotline (1-800-426-4791)**.

# Cheltenham Youth Facility Treated Water Quality Report 2022

## Definitions:

- ◆ **Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ◆ **Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- ◆ **Action Level** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow
- ◆ **Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water
- ◆ **Turbidity** - Relates to a condition where suspended particles are present in the water. Turbidity measurements are a way to describe the level of “cloudiness” of the water.
- ◆ **pCi/l** - Picocuries per liter. A measure of radiation.
- ◆ **ppb** - parts per billion or micrograms per liter
- ◆ **ppm** - parts per million or milligrams per liter
- ◆ **ppt** - parts per trillion or nanograms per liter

## Lead Prevention

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Water Treatment Plant is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, please contact [jjanney@menv.com](mailto:jjanney@menv.com) for a list of laboratories in your area that provide drinking water testing. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some compounds. The presence of these compounds does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **Environmental Protection Agency's (EPA's) Safe Drinking Water Act Hotline (1-800-426-4791)**



## Cheltenham Youth Facility Treated Water Quality Report 2022

Contaminant	Highest Level Allowed (EPA's MCL)	Highest Level Detected	Ideal Goal (EPA's MCLG)
<b>Regulated at the Treatment Plant</b>			
Barium (2022 Testing)	2000 ppb	150 ppb	2000 ppb
Typical Source of Contamination: Erosion of natural deposits		(Range 140 - 150 ppb)	
<b>Regulated in the Distribution System</b>			
Chlorine	4 ppm	1.19 ppm	4 ppm
Source: Water additive to control microbes.		(Range: 0.86- 1.19 ppm)	
*Annual Rolling Average			
Total Trihalomethanes (TTHM) (2020 Testing)	80 ppb	8.3 ppb	n/a
Typical Source of Contamination: By-product of drinking water disinfection			
Haloacetic Acids (HAA5) (2020 Testing)	60 ppb	5.1 ppb	n/a
Typical Source of Contamination: By-product of drinking water disinfection			
<b>Regulated in the Distribution System</b>			
	Action Level)	90th percentile	Ideal Goal
Copper (2021 Testing)	1300 ppb	370 ppb	1300 ppb
Typical Source of Contamination: Corrosion of household plumbing fixtures and systems			
Lead (2021 Testing)	15 ppb	2.0 ppb	0 ppb
Typical Source of Contamination: Corrosion of household plumbing fixtures and systems			

The table above lists all the drinking water contaminants that were detected during the 2022 calendar year. The presence of these compounds in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in the table is from testing done January 1 – December 31, 2022. The State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

## Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases radioactive material, and can pick up substances resulting from the presence of animals or from

*In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain compounds in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.*



## Important information Regarding Gross Alpha Emitters:

Alpha emitters are naturally occurring radiations in soil, air and water. These emitters generally occur when certain elements decay or break down in the environment. The emitters enter drinking water through various methods including the erosion of natural deposits. There are no immediate health risks from consuming water that contains gross alpha, however some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer. Currently, the highest level of gross alpha detected is 2.1 pCi/L which is below the 15 pCi/L MCL.

## Contaminants That May Be Present in Source Water:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. Inorganic Contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming. Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems. Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

*If you have any questions about this report or your drinking water, please call Jay Janney at 410-729-8350 or email your request to [jjanney@menv.com](mailto:jjanney@menv.com).*





# Cheltenham Youth Facility Treated Water Quality Report 2022

## Polyfluoroalkyl Substances

PFAS – or per- and polyfluoroalkyl substances – refers to a large group of more than 4,000 human-made chemicals that have been used since the 1940s in a range of products, including stain- and water-resistant fabrics and carpeting, cleaning products, paints, cookware, food packaging and fire-fighting foams. These uses of PFAS have led to PFAS entering our environment, where they have been measured by several states in soil, surface water, groundwater, and seafood. Some PFAS can last a long time in the environment and in the human body and can accumulate in the food chain. Beginning in 2020, the Maryland Department of the Environment (MDE) initiated a PFAS monitoring program. PFOA and PFOS are two of the most prevalent PFAS compounds. PFOA and PFOS concentrations were measured from samples taken at both Raw water sample points to your water system in 2022 and are listed below. PFOA results were <1.0 (non-detect) parts per trillion (ppt) and <1.0ppt (non-detect). PFOS results were <1.0 (non-detect) parts per trillion (ppt) and <1.0ppt (non-detect). In March 2023, EPA announced proposed Maximum Contaminant Levels (MCLs) of 4 ppt for PFOA and 4 ppt for PFOS, and a Group Hazard Index limit of 1 (unitless) for four additional PFAS compounds (PFHxS, GenX Chemicals, PFNA and PFBS). The four (4) additional PFAS parameters were also analyzed in 2022 with group hazard indexes of 0.00 and 0.00. Future regulations would require additional monitoring as well as certain actions for systems above the MCLs or Hazard Index. EPA will publish the final MCLs and requirements by the end of 2023 or beginning of 2024. Additional information about PFAS can be found on the MDE website: [mde.maryland.gov/PublicHealth/Pages/PFAS-Landing-Page.aspx](https://mde.maryland.gov/PublicHealth/Pages/PFAS-Landing-Page.aspx).

### Boys Village 2 PG731183

PFAS parameters	Result	Proposed limit	PFAS parameters	Result	Proposed limit (* unitless number used to calculate Hazard index)
PFOS	<1.0 ppt	4.0 ppt	PFHxS	<1.0 ppt	9 ppt
PFOA	<1.0 ppt	4.0 ppt	GenX Chemicals	<1.0 ppt	10 ppt
			PFNA	<1.5 ppt	10 ppt
			PFBS	<1.0 ppt	2000 ppt
			Hazard Index	0.00 *	1.0 *

### Boys Village 1 PG024111

PFAS parameters	Result	Proposed limit	PFAS parameters	Result	Proposed limit (* unitless number used to calculate Hazard index)
PFOS	<1.0 ppt	4.0 ppt	PFHxS	<1.0 ppt	9 ppt
PFOA	<1.0 ppt	4.0 ppt	GenX Chemicals	<1.0 ppt	10 ppt
			PFNA	<1.5 ppt	10 ppt
			PFBS	<1.0 ppt	2000 ppt
			Hazard Index	0.00*	1.0 *